# Interior Health Authority

## Sample History: Sample Parameter Report

*Filtered by: Sample Date From: 5/13/2013, Sample Date To: 7/5/2013, Sample Type: Drinking Water - Bacteriological, Include Acceptable Parameter Results, Facility Category Group: Water Systems, Region: Thompson/Cariboo/Shuswap [Corp 1001-71]*

## Queest Village Water System

Site: Queest Access Road , Sicamous, BC

Owner: The Owners Strata Plan K611

**Drinking Water - Bacteriological**

| Sample Parameter | Sample Identifier | Date Collected | Result | UOM | |
|---|---|---|---|---|---|
| **Queest Village Water System** | | | | | |
| **5/20/2013** | | | | | |
| **Total Coliform** | | | | | |
| | 1835 | 5/20/2013 | 11 | 100ml | Unacceptable |
| | 1836 | 5/20/2013 | 3 | 100ml | Unacceptable |
| | | | | **Total Coliform Total:** | **2** |
| **E. coli** | | | | | |
| | 1835 | 5/20/2013 | < 1 | 100ml | Acceptable |
| | 1836 | 5/20/2013 | < 1 | 100ml | Acceptable |
| | | | | **E. coli Total:** | **2** |
| | | | | **5/20/2013 Total:** | **4** |
| | | | | **Queest Village Water System Total:** | **4** |