Interior Health Authority

Box 627, 851 - 16th Street Salmon Arm, BC V1E 4N7
Phone Number: (250) 833-4100 Fax Number: 250-833-4117

Drinking Water - Bacteriological

Facility Information:

Queest Village Water System
The Owners Strata Plan K611
Queest Access Road

Phone: **Fax:**

Report Date:	July 17, 2013
Facility Number:	14-098-00056
Community:	Sicamous
Requisition Number:	2013021900100
Sample Date:	May 20, 2013
Lab Sample ID:	1835
Taken By:	Colin Black
Service Provider:	Brian Gregory

Sample Site:	Tap @Unit 21	**Sample Site Code:**	D01FLONON2
Sample Site Address:	Queest Access Road		
On Boil Water Notice?	Yes	**Date of Initial Notice:**	6/2/2010

Facility Category: Water System 15-300 Connections, Strata Corporation

General Comments:

May 22/13 PMakeiff - site is at black cabin tap

Parameter	Results	Units	Result Interpretation	
Parameter Interpretation				
Health				
Total Coliform	= 11	100ml	High Severity >=1	*

Total coliform bacteria are used to indicate contamination of the water source or supply. Total coliform are found in decaying vegetation and may indicate that fecal contamination has occurred. Microbiological standard: Part A) 1 sample in a 30 day period, no detectable total coliform bacteria per 100 ml. Part B) At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml.

Interior Health Authority

Box 627, 851 - 16th Street Salmon Arm, BC V1E 4N7
Phone Number: (250) 833-4100 Fax Number: 250-833-4117

Drinking Water - Bacteriological

Facility Information:

Queest Village Water System
The Owners Strata Plan K611
Queest Access Road

Phone: **Fax:**

Report Date:	July 17, 2013
Facility Number:	14-098-00056
Community:	Sicamous
Requisition Number:	2013021900098
Sample Date:	May 20, 2013
Lab Sample ID:	1836
Taken By:	Colin Black
Service Provider:	Anita Ely

Sample Site:	Queest Creek RAW	**Sample Site Code:**	E01FLONON2
Sample Site Address:	Queest Access Road		
On Boil Water Notice?	Yes	**Date of Initial Notice:**	6/2/2010
Facility Category:	Water System 15-300 Connections, Strata Corporation		

Parameter	Results	Units	Result Interpretation	
Parameter Interpretation				
Health				
Total Coliform	= 3	100ml	High Severity >=1	*

Total coliform bacteria are used to indicate contamination of the water source or supply. Total coliform are found in decaying vegetation and may indicate that fecal contamination has occurred. Microbiological standard: Part A) 1 sample in a 30 day period, no detectable total coliform bacteria per 100 ml. Part B) At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml.