Interior Health Authority

Sample History: Sample Parameter Report

Filtered by: Facility Name: Queest, Sample Type: Drinking Water - Bacteriological, Include Acceptable Parameter Results, Service Provider Responsible: Mrowietz, Tanya

Queest Village Water System

Site: Queest Access Road , Sicamous, BC

Owner: The Owners Strata Plan K611

Drinking Water - Bacteriological

Sample Parameter	Sample Identifier	Date Collected	Result	UOM	
Total Coliform					
	2163	6/2/2010	34	100ml	Unacceptable
	2164	6/2/2010	15	100ml	Unacceptable
				Total Coliform Total:	**2**
E. coli					
	2163	6/2/2010	1	100ml	Unacceptable
	2164	6/2/2010	< 1	100ml	Acceptable
				E. coli Total:	**2**
				Report Total:	**4**